

NOTES: <u>Service Clearance Requirements</u> 1. SERVICE CLEARANCES TO BE IN CONFORMANCE TO NEC REQUIREMENTS. ALLOW A MINIMUM OF 36" CLEARANCE IN FRONT OF DOORS FOR SERVICING OF HEATING ELEMENTS. RECOMMENDED 24" CLEARANCE FOR OTHER SIDES OF BOILER FOR SERVICING. 2. MINIMUM 2" CLEARANCE TO ALL COMBUSTIBLE MATERIALS 3. MINIUMUM 18" CLEARANCE ON TOP TO COMBUSTIBLE MATERIALS 2.00 24.00 **DIMENSIONS ARE SHOWN IN INCHES [CENTIMETERS]** TOLERANCES ARE AS FOLLOWS UNLESS OTHERWISE SPECIFIED X.XX X.XXX X.XXXX ANGULAR FINISH **CHT** ELECTRIC BOILERS <u>+</u> .12 <u>+</u> .031 <u>+</u> .0156 <u>+</u>1.0° 439 MAIN RD. TOWACO NJ 07082 REMOVE AND DEBURR SHARP EDGES AND CORNERS ALL DIMENSIONS ARE AFTER FINISH OR PLATING REFERENCE DIMENSIONS ARE SHOWN IN PARENTHESES () CRITICAL DIMENSIONS ARE SHOWN IN PHONE: (800) 221-1522 FAX: (718) 386-7809 EWx630-EWx960 ELECTRIC WATER TITLE THIS DRAWING AND/OR SPECIFICATIONS ARE THE PROPERTY OF DIVERSIFIED HEAT TRANSFER INC. THIS CONFIDENTIAL AND PROPRIETARY INFORMATION SHALL NOT BE **BOILERS** USED, COPIED OR REPRODUCED IN ANY MEANS AS THE BASIS FOR MANUFACTURE OR SALE OF APPARATUS WITHOUT WRITTEN AUTHORIZATION FROM OWNER. 1/15/25 FOR RELEASE DWG# THIRD ANGLE PROJECTION DWG. SCALE MATERIAL SPEC: NAME DATE REV EWx630-EWx960 JH DRAWN BY 10/24/24 **REVISION DESCRIPTION** Α **ECN** NAME DATE CHECKED BY SHEET 2 OF 2